



NOTE: 1) HYDRO @ 325 PSIG. MIN.

SHELL / HEADS	.245" SA-455 2:1 S.E.
JOGGLE	
	.288" SA-455
M.A.W.P.	250 PSIG. @ 200 °F
M.D.M.T.	-20 °F @ 250 PSIG.
ASME SECTION VIII	DIV. 1, 2001 ADD. 2003
X-RAY:	RT-4 SPOT L.S. & HDS. G.S.
GALLONS:	575 WT. 1540 LBS.
SERIAL NO.	
N.B.	

<b>PA-496-B</b>	REV. 9-2-04
FOR: HANSON STANDARD	DATE: 7-31-03
HORIZ. PROPANE TANK DISPENSER	
CFM REQ. = 2407	
SURFACE AREA = 103.2 SQ. FT.	
INSIDE: UNPAINTED & DEHYDRATE	
OUTSIDE: PRIME	
BY: J.G.	
<b>ROY E. HANSON JR. MFG.</b>	
1924 COMPTON AVE.	
LOS ANGELES, CA 90011	