



NOTE: 1) HYDRO @ 325 PSIG. MIN.

HEADS		.245" SA-455 2:1 S.E.	
SHELL		.289" SA-455	
M.A.W.P.		250 PSIG. @	200 °F
M.D.M.T.		-20 °F @	250 PSIG.
ASME. SECTION VIII DIV. 1, 2010 ADD. 2010			
X-RAY:		RT-4 SPOT L.S. & HDS. G.S.	
GALLONS:	1000	WT.	2329 LBS.
SERIAL NO.			
N.B.			

PA-515-B		REV. 7-27-11
FOR: HANSON STANDARD		DATE: 1-2-90
HORIZ. PROPANE TANK DISPENSER		
CFM REQ. = 3654		
SURFACE AREA = 172.1 SQ. FT.		
INSIDE: UNPAINTED & DEHYDRATE		
OUTSIDE: PRIME & WHITE		
BY: J.G.	SCALE: 1/2"=12"	
ROY E. HANSON JR. MFG.		
1600 E. WASHINGTON BLVD.		
LOS ANGELES, CA 90021		