



| SHELL / HEADS |                            |
|---------------|----------------------------|
| M.A.W.P.      | 150 PSIG. @ 200 °F         |
| M.D.M.T.      | -20 °F @ 125 PSIG.         |
| ASME SECTION  | VIII DIV. 1, 2007 ADD 2007 |
| X-RAY:        | RT-NO                      |
| GALLONS:      | 120                        |
| WT.           | 326 LBS.                   |
| SERIAL NO.    |                            |
| N.B.          |                            |

NOTE: 1) HYDRO @ 197 PSIG. MIN.  
 2) WELD 1/2" Ø ROUND BARS TO SHELL AFTER HEADS ARE IN PLACE.

|                               |               |
|-------------------------------|---------------|
| <b>WM-182-B</b>               | REV. 10-6-08  |
| FOR: VERT. CHILLED WATER TANK | DATE: 1-15-08 |
| SURFACE AREA = 35.9 SQ. FT.   |               |
| INSIDE: UNPAINTED             |               |
| OUTSIDE: PRIME                |               |
| BY: E.S. / C.J.               | SCALE: 1"=12" |
| <b>ROY E. HANSON JR. MFG.</b> |               |
| 1600 E. WASHINGTON BLVD.      |               |
| LOS ANGELES, CA 90021         |               |