



SHELL / HEADS		NOTE: 1) HYDRO @ 195 PSIG. MIN.	
M.A.W.P.	150 PSIG. @ 200 °F	2) WELD 3/4" Ø ROUND BARS TO SHELL AFTER HEADS ARE IN PLACE.	
M.D.M.T.	+20 °F @ 150 PSIG.		
ASME SECTION VIII	DIV. 1, 2007 ADD. 2008		
X-RAY:	RT-NO		
GALLONS:	500		
SERIAL NO.	WT. 1222 LBS.		
N.B.			
FOR: VERT. CHILLED WATER TANK		WM-624-B	
SURFACE AREA = 91.6 SQ. FT.		REV. 7-20-09	
INSIDE: UNPAINTED		DATE: 3-9-09	
OUTSIDE: PRIME			
BY: J.G./FRED		SCALE: 3/4"=12"	
ROY E. HANSON JR. MFG.		1600 E. WASHINGTON BLVD.	
		LOS ANGELES, CA 90021	

NOTE: 1) HYDRO @ 195 PSIG. MIN.  
 2) WELD 3/4" Ø ROUND BARS TO SHELL AFTER HEADS ARE IN PLACE.

