



SHELL / HEADS	
M.A.W.P.	125 PSIG. @ 200 °F
M.D.M.T.	0 °F @ 125 PSIG.
ASME SECTION	VIII DIV. 1, 2007 ADD. 2008
X-RAY:	RT-NO
GALLONS:	800
SERIAL NO.	WT. 1571 LBS.
N.B.	

NOTE. 1) 2) HYDRO @ 163 PSIG. MIN. WELD 3/4" Ø ROUND BARS TO SHELL AFTER HEADS ARE IN PLACE

FOR: WM-639-B	
DATE:	3-20-09
REV.	4-2-09
SCALE:	3/4"=12"
BY:	J.G./B.C.
LEG-ZONE	3-15 KM.
OUTSIDE:	PRIME
INSIDE:	UNPAINTED
SURFACE AREA	= 127.9 SQ. FT.
VERT. CHILLED WATER TANK	
UW-21(b)	
ROY E. HANSON JR. MFG.	
1600 E. WASHINGTON BLVD.	
LOS ANGELES, CA 90021	

