





NOTE: 1) WELD 3/4"ø ROUND BARS TO SHELL AFTER HEADS ARE IN PLACE.
2) HYDRO @ 163 PSIG. MIN.

SHELL / HEADS	
M.A.W.P. 125 PSIG. @ 150 °F	.140" SA–414–G 2:1 S.E.
M.D.M.T. 0 °F @ 125 PSIG.	.200" SA–455
ASME. SECTION VIII DIV. 1, 2007 ADD 2009	JOGGLE – .149" OFFSET
X–RAY: RT–NO	
GALLONS: 160	
WT. 456 LBS.	

N.B.

SERIAL NO.

WN–056–B	REV. 10–1–10
	DATE: 10–1–10
FOR: –	
VERT. CHILLED WATER TANK	
SURFACE AREA = 41.9 SQ. FT.	
UW–21(b)	
INSIDE: UNPAINTED	
OUTSIDE: PRIME & R–16	
LEG–ZONE 4–2 KM.	
BY: E.S. / R.L.	SCALE: 1"=12"

ROY E. HANSON JR. MFG.
1600 E. WASHINGTON BLVD.
LOS ANGELES, CA 90021