



4"-150# R.F.S.O.
 FLG. W/ SCH. 40
 SA-106-B
 PIPE x 7 1/16" LG.
 (2) PLC'S.

NOTE: 1) 2) WELD 3/4"Ø ROUND BARS TO SHELL AFTER HEADS ARE IN PLACE.
 HYDRO @ 195 PSIG. MIN.

SHELL / HEADS		M.A.W.P. 150 PSIG. @ 200 °F	
.140" SA-414-G 2:1 S.E.		M.D.M.T. 0 °F @ 150 PSIG.	
JOGGLE - .149" OFFSET		ASME. SECTION VIII DIV. 1, 2010 ADD 2010	
.175" SA-414-G		X-RAY: RT-NO	
		GALLONS: 250	
		WT. 633 LBS.	
		SERIAL NO.	
		N.B.	
FOR: -		WN-163-B	
VERT. CHILLED WATER TANK		REV. DATE: 2-9-11	
SURFACE AREA = 61.7 SQ. FT.			
UW-21(b)			
INSIDE: UNPAINTED			
OUTSIDE: S. BLAST, INORGANIC			
ZINC PRIME			
BY: E.S. / C.J. SCALE: 1"=12"			
ROY E. HANSON JR. MFG.			
1600 E. WASHINGTON BLVD.			
LOS ANGELES, CA 90021			