



VIEW W/O SUPPORTS

- 4) 3-19-09 PROOF TEST.
- 3) EXTEND ALL CPLGS. 5/8" INSIDE.
- 2) HYDRO @ 240 PSIG.

NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.

SHELL / HEADS	.205" SA-455 2:1 S.E.	CS-42-534-H	REV. 6-14-11	
	JOGGLE		DATE: 7-23-91	
		FOR: HANSON STANDARD	HORIZ. HOT WATER TANK	
	.175" SA-414-G	94.1 SQ. FT. SURFACE AREA. THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT		
M.A.W.P. 160 PSIG. @ 210 °F	INSIDE: CEMENT LINED			
	OUTSIDE: PRIME			
ASME. SECTION IV 2010 ADD 2010	CAD "B" SIZE UNDER "STD"-SERIES			
X-RAY: RT-NO / H.L.W.	BY: E.S.		SCALE: 3/4"=12"	
GALLONS: 534	WT. 1583 LBS.	<b>ROY E. HANSON JR. MFG.</b>		
SERIAL NO.	1600 E. WASHINGTON BLVD.			
N.B.	LOS ANGELES, CA 90021			