



VIEW W/O SUPPORTS

- 4) 3-19-09 PROOF TEST.
- 3) EXTEND ALL CPLGS. 5/8" INSIDE.
- 2) HYDRO @ 240 PSIG.

NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.

SHELL / HEADS	.205" SA-455 2:1 S.E.	CS-42-660-H	REV. 6-14-11
	JOGGLE		DATE: 7-15-02
	.175" SA-414-G	FOR: HANSON STANDARD	
		HORIZ. HOT WATER TANK	
	115.8 SQ. FT. SURFACE AREA. THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT		
	INSIDE: CEMENT LINED		
	OUTSIDE: PRIME		
	CAD "B" SIZE UNDER "STD"-SERIES		
	BY: E.S.		SCALE: 3/4"=12"
	ROY E. HANSON JR. MFG.		
	1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021		
	M.A.W.P. 160 PSIG. @ 210 °F		
	ASME. SECTION IV 2010 ADD 2010		
	X-RAY: RT-NO / H.L.W.		
	GALLONS: 660	WT. 1907 LBS.	
	SERIAL NO.		
	N.B.		