



VIEW W/OUT SUPT'S

3) EXTEND ALL CPLGS. 5/8" INSIDE.  
 2) HYDRO @ 163 PSIG.  
 NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.

HEADS	.248" SA-455 2:1 S.E.
	(.211" MIN.)
SHELL	.207" SA-455
M.A.W.P. 125 PSIG. @ 210 °F	
M.D.M.T. -20 °F @ 125 PSIG.	
ASME. SECTION VIII DIV. 1, 2001 ADD 2003	
X-RAY: RT-4 SPOT L.S. & HDS. G.S.	
GALLONS:	1450
WT.	3280 LBS.
SERIAL NO.	
N.B.	

CS-60-1450-H	REV. 9-21-04
	DATE: 10-5-89
FOR: HANSON STANDARD	
HORIZ. WATER TANK.	
180.2 SQ. FT. SURFACE AREA. THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.	
INSIDE: CEMENT LINED (1395)	
OUTSIDE: PRIME	
CAD "B" SIZE UNDER "STD"-SERIES	
BY: J.G.	SCALE: 1/2"=12"
<b>ROY E. HANSON JR. MFG.</b>	
1924 COMPTON AVE. LOS ANGELES, CA 90011	