



VIEW W/OUT SUPPORTS

NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.
 2) HYDRO @ 188 PSIG. MIN. TO 197 PSIG. MAX.
 3) EXTEND ALL CPLGS. 5/8" INSIDE.

SHELL / HEADS	LEFT-.248" SA-455 2:1 S.E. (.212" MIN.)	CS-64-1650-H	REV. 9-4-07
	RIGHT-.289" SA-455 2:1 S.E. (.235" MIN.)		DATE: 10-23-89
	.250" SA-455	FOR: HANSON STANDARD HORIZ. WATER TANK	
	M.A.W.P. 125 PSIG. @ 210 °F	197.0 SQ. FT. SURFACE AREA. THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.	
ASME. SECTION IV 2004 ADD. 2006	INSIDE: CEMENT LINED (1583)		OUTSIDE: PRIME
X-RAY: RT-NO / H.L.W.	CAD-"B" UNDER "STD"-SERIES		BY: J.G. SCALE: 1/2"=12"
GALLONS: 1650 WT. 3800 LBS.	ROY E. HANSON JR. MFG. 1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021		
SERIAL NO.			
N.B.			