



VIEW W/O SUPPORTS

NOTE: 1) 4-1-04 PROOF TEST.
 2) HYDRO @ 240 PSIG. MIN.

SHELL / HEADS		.164" SA-414-G 2:1 S.E.	
JOGGLE			
M.A.W.P.		160	PSIG. @ 180 °F
ASME SECTION IV		2013	
X-RAY:		RT-NO / H.L.W.	
GALLONS:		140	WT. 360 LBS.
SERIAL NO.			
N.B.			
FOR: HANSON STANDARD		REV. 2-21-14	
HORIZ. HOT WATER TANK		DATE: 3-2-90	
SURFACE AREA = 37.5 SQ. FT.			
INSIDE: EPOXY LINED			
OUTSIDE: PRIME			
CAD-"B" UNDER "STD"-SERIES			
BY: E.S.		SCALE: 1"=12"	
ROY E. HANSON JR. MFG.			
1600 E. WASHINGTON BLVD.			
LOS ANGELES, CA 90021			