



NOTE. 1) 8-26-04 PROOF TEST.  
 2) HYDRO @ 188 PSIG. MIN. TO 197 PSIG. MAX.

HEADS	.250" SA-455 2:1 S.E. (.210" MIN.)	REV. 6-19-12
SHELL	.248" SA-455	DATE: 4-14-03
M.A.W.P.	125 PSIG. @ 180 °F	FOR: HANSON STANDARD
ASME SECTION	IV 2010 ADD 2011	HORIZ. HOT WATER TANK.
X-RAY:	RT-NO/HL.W.	SURFACE AREA = 215.0 SQ.FT.
GALLONS:	1950 WT. 2928 LBS.	INSIDE: EPOXY LINED
SERIAL NO.		OUTSIDE: PRIME
N.B.		CAD "B" SIZE UNDER "STD"-SERIES
		BY: J.G. SCALE: 1/2"=12"
		<b>ROY E. HANSON JR. MFG.</b>
		1600 E. WASHINGTON BLVD.
		LOS ANGELES, CA 90021