



NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.
 2) HYDRO @ 163 PSIG. MIN.
 3) EXTEND ALL CPLGS. 5/8" INSIDE.

BOLT-ON SADDLE
 PER: WI-577-B-1A

SHELL / HEADS		.280" SA-455 2:1 S.E. (.248" MIN.)	
M.A.W.P. 125 PSIG. @ 210 °F		M.D.M.T. -20 °F @ 125 PSIG.	
ASME SECTION VIII DIV. 1, 2001 ADD 2003		X-RAY: RT-4 SPOT L.S. NOT G.S.	
GALLONS: 1950		WT. 4363 LBS.	
SERIAL NO.		N.B.	
FOR: HANSON TANK		CS-72-1950-H	
HORIZ. WATER TANK.		REV. 7-23-04	
215.0 SQ. FT. SURFACE AREA.		DATE: 4-14-03	
THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.		SCALE: 1/2"=12"	
INSIDE: CEMENT LINED (1874)		BY: J.G.	
OUTSIDE: PRIME		CAD "B" SIZE UNDER "STD"-SERIES	
ROY E. HANSON JR. MFG.		1924 COMPTON AVE.	
LOS ANGELES, CA 90011			