



- 4) ALL PIPES SA-312-304 SMLS.
- 3) SHELL: 3-11-09 PROOF TEST.
- 2) HYDRO @ 240 PSIG. MIN.
- NOTE: 1) INSTALL (2) 1 5/16"x 36"LG. RIGID MAG. ANODES.

SHELL / HEADS	.205" SA-414-G 2:1 S.E.	WP-681-B	REV.
	JOGGLE		DATE: 6-5-18
			FOR: HANSON STANDARD
			HORIZ. HOT WATER TANK
	.175" SA-414-G		SURFACE AREA = 91.4 SQ. FT.
			INSIDE: GLASS LINED (5 MILS MIN.)
			OUTSIDE: S. BLAST AND PRIME
	M.A.W.P. 160 PSIG. @ 210 °F		
	ASME SECTION IV 2017		
	X-RAY: RT-NO / H.L.W.		
	GALLONS: 499	WT. 1060 LBS.	BY: J.G. SCALE: 3/4"=12"
	SERIAL NO.		ROY E. HANSON JR. MFG.
	N.B.		LOS ANGELES, CA 90021