



NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.
 2) HYDRO @ 163 PSIG. MIN.
 3) EXTEND ALL CPLGS. 5/8" INSIDE.

HEADS	.280" SA-455 2:1 S.E. (.248" MIN.)		CS-72-2150-H	REV. 7-23-04
				DATE: 4-15-03
SHELL	.250" SA-455		FOR: HANSON TANK	
			HORIZ. WATER TANK.	
M.A.W.P. 125 PSIG. @ 210 °F			232.0 SQ. FT. SURFACE AREA.	
M.D.M.T. -20 °F @ 125 PSIG.			THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.	
ASME. SECTION VIII DIV. 1, 2001 ADD 2003			INSIDE: CEMENT LINED (2077)	
X-RAY: RT-4 SPOT L.S. NOT G.S.			OUTSIDE: PRIME	
GALLONS: 2150		WT. 4690 LBS.	CAD "B" SIZE UNDER "STD"-SERIES	
SERIAL NO.			BY: J.G. SCALE: 1/2"=12"	
N.B.			ROY E. HANSON JR. MFG.	
1924 COMPTON AVE. LOS ANGELES, CA 90011				