



NOTE: 1) WELD 3/4"Ø ROUND BARS TO SHELL AFTER HEADS ARE IN PLACE.
 2) HYDRO @ 197 PSIG. MIN.

SHELL / HEADS		.135" SA-414-G 2:1 S.E.	
JOGGLE			
M.A.W.P.	150 PSIG. @ 200 °F		
M.D.M.T.	0 °F @ 150 PSIG.		
ASME SECTION VIII	DIV. 1, 2004 ADD 2005		
X-RAY:	RT-NO		
GALLONS:	120	WT.	381 LBS.
SERIAL NO.			
N.B.			
FOR: VERT. CHILLED WATER TANK		WL-626-B	
SURFACE AREA = 37.5 SQ. FT.		REV. DATE: 8-15-06	
INSIDE: UNPAINTED			
OUTSIDE: PRIME & R-16			
BY: E.S. / H.D. SCALE: 1"=12"			
ROY E. HANSON JR. MFG.			
1600 E. WASHINGTON BLVD.			
LOS ANGELES, CA 90021			