



6"-150# R.F.S.O.
 FLG. W/ SCH. 40
 PIPE x 7 9/16" LG.
 (4) PLC'S.

1/2"Ø L.LUG
 (1) PLC.

2"R (15"R)
 W/ C.I. PLUG FOR
 INSP. OPENINGS
 (2) PLC'S.

(3) 2 1/2" x 2 1/2" x 3/16" THK.
 x 23 3/4" LG. ANGLE LEGS
 (3) 4" x 4" x 1/4" THK.
 PAD W/ 1"Ø HOLES
 FOR 3/4" BOLTS

(2) 2"
 IN LINE

NOTE: 1) HYDRO @ 165 PSIG. MIN.

SHELL / HEADS	
JOGGLE	.182" SA-455 2:1 S.E.
	.164" SA-414-G
M.A.W.P.	125 PSIG. @ 200 °F
M.D.M.T.	0 °F @ 125 PSIG.
ASME SECTION VIII	DIV. 1, 2004 ADD 2005
X-RAY:	RT-NO
GALLONS:	250 WT. 566 LBS.
SERIAL NO.	
N.B.	
FOR: VERT. CHILLED WATER TANK	
INSIDE: UNPAINTED	
OUTSIDE: PRIME	
LEG-ZONE 1-15 KM.	
BY: E.S. / H.D.	SCALE: 1" = 12"
ROY E. HANSON JR. MFG.	
1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021	
REV:	WL-712-B
DATE:	11-7-06

