



SHELL / HEADS		NOTE. 1) WELD 3/4"φ ROUND BARS TO SHELL AFTER HEADS ARE IN PLACE	
M.A.W.P.	125 PSIG. @ 200 °F	.245" SA-455	2) HYDRO @ 163 PSIG. MIN.
M.D.M.T.	0 ° F @ 125 PSIG.	JOGGLE - .199 OFFSET	
ASME SECTION	VIII DIV. 1, 2010 ADD. 2010		
X-RAY:	RT-NO		
GALLONS:	800		
SERIAL NO.	WT. 1840 LBS.		
N.B.			
FOR: VERT. CHILLED WATER TANK		WL-776-B	
SURFACE AREA = 127.9 SQ. FT.		REV. 12-14-11	
INSIDE: UNPAINTED		DATE: 1-9-07	
OUTSIDE: PRIME			
LEG-ZONE 4-10 KM.			
BY: J.G./C.J.			
SCALE: 3/4"=12"			
ROY E. HANSON JR. MFG.			
1600 E. WASHINGTON BLVD.			
LOS ANGELES, CA 90021			