DATE	BY
2-24-14	RH







NOTE: 1) 2) WELD 3/4"ø ROUND BARS TO SHELL AFTER HEADS ARE IN PLACE. HYDRO @ 195 PSIG. MIN.

SHELL / HEADS	
.250" SA-414-G 2:1 S.E.	.248" SA-455
JOGGLED	

M.A.W.P. 150 PSIG. @	200 °F
M.D.M.T. 0 °F @	150 PSIG.
ASME. SECTION VIII DIV. 1, 2013	
X-RAY: RT-NO	
GALLONS: 500	WT. 1482 LBS.
SERIAL NO.	
N.B.	

WO-138-B	REV.
FOR:	DATE: 2-21-14
VERT. CHILLED WATER TANK	
SURFACE AREA = 85.9 SQ. FT.	
UW-21(b)	
INSIDE: UNPAINTED	
OUTSIDE: SHOP PRIME	
BY: E.S. / C.J.	SCALE: 3/4"=12"

ROY E. HANSON JR. MFG.
1600 E. WASHINGTON BLVD.
LOS ANGELES, CA 90021