



DATE	BY
10-16-14	JG

SHELL / HEADS	
M.A.W.P.	125 PSIG. @ 210 °F
ASME SECTION IV	2013
X-RAY:	RT-NO / H.L.W.
GALLONS:	3000 WT. 5745 LBS.
SERIAL NO.	N.B.
LEG-ZONE	1-15 KM.
	.218" SA-455
	(.230" MIN.)
	.250" SA-455 2:1 S.E.

- NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.
- 2) HYDRO @ 188 PSIG. MIN. TO 197 PSIG. MAX.
 - 3) EXTENDE ALL CPLGS. 5/8" INSIDE.
 - 4) ALL CPLGS. SA-182-304 S.S.
 - 5) ALL PIPES SA-312-304.
 - 6) 5-6-04 PROOF TEST.

FOR:	WO-365-B
DATE:	10-15-14
REV.	
VERT. HOT WATER TANK	
350.9 SQ. FT. SURFACE AREA.	
THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.	
INSIDE: CEMENT LINED	
OUTSIDE: S. BLAST, INORGANIC ZINC PRIME & R-16	
BY: E.S. / B.C. SCALE: 3/8"=12"	
ROY E. HANSON JR. MFG.	
1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021	

