



SHELL / HEADS		TOP-.187" SA-240-316 2:1 S.E.		TRIM		BTM-.250" SA-240-316 2:1 S.E.	
M.A.W.P. 125 PSIG. @ 240 °F		M.D.M.T. 32 °F @ 125 PSIG.		ASME SECTION VIII DIV. 1, 2013		X-RAY: RT-4 SPOT L.S. ONLY	
GALLONS: 793		WT. 1450 LBS.		SERIAL NO.		N.B.	
DATE: 7-16-14		REV. 7-23-14		FOR: VERT. BLADDER TANK		SURFACE AREA = 137.3 SQ. FT.	
INSIDE: PASSIVATED		OUTSIDE: BEAD BLAST & PASSIVATE		LEG-ZONE 3-15 KM.		BY: E.S. / STEVE SCALE: 3/4"=12"	
1600 E. WASHINGTON BLVD.		LOS ANGELES, CA 90021		ROY E. HANSON JR. MFG.			

NOTE: 1) HYDRO @ 163 PSIG. MIN.
 2) FOR NON CORROSIVE SERVICE-BLADDER TANK.
 3) ALL FNPT'S SA-182-316 S.S.
 4) ALL 316 S.S. CONSTRUCTION.

DATE	BY
7-16-14	JG
7-23-14	JG