



2) SHELL - 4-22-04 PROOF TEST.
NOTE: 1) HYDRO @ 240 PSIG.

SHELL / HEADS	.245" SA-455 2:1 S.E. (.230" MIN.) JOGGLE	ES-48-712-H	REV. 9-17-04
			DATE: 10-3-89
		FOR: HANSON STANDARD HORIZ. HOT WATER TANK	
	.200" SA-455	SURFACE AREA = 113.0 SQ. FT. INSIDE: EPOXY LINED	
	M.A.W.P. 160 PSIG. @ 180 °F	OUTSIDE: PRIME	
	ASME SECTION IV 2001 ADD. 2003	CAD-"B" UNDER "STD"-SERIES	
	X-RAY: RT-NO/H.L.W.	BY: J.G.	SCALE: 3/4"=12"
	GALLONS: 712	WT. 1161 LBS.	ROY E. HANSON JR. MFG.
	SERIAL NO.	1924 COMPTON AVE. LOS ANGELES, CA 90011	