



VIEW W/O SUPPORTS

2) SHELL: 4-22-04 PROOF TEST.  
NOTE: 1) HYDRO @ 240 PSIG. MIN.

SHELL / HEADS	.250" SA-455 2:1 S.E.	ES-48-900-H	REV. 12-21-15
	JOGGLE (.230" MIN.)		DATE: 10-3-89
	.200" SA-455	FOR: HANSON STANDARD	
		HORIZ. HOT WATER TANK	
M.A.W.P. 160 PSIG. @ 210 °F		SURFACE AREA = 138.4 SQ. FT.	
ASME SECTION IV 2015		INSIDE: EPOXY LINED	
X-RAY: RT-NO / H.L.W.		OUTSIDE: PRIME	
GALLONS: 900	WT. 1350 LBS.	CAD-"B" UNDER "STD"-SERIES	
SERIAL NO.		BY: E.S.	SCALE: 3/4"=12"
N.B.		<b>ROY E. HANSON JR. MFG.</b>	
		LOS ANGELES, CA 90021	