



- 3) SHELL: 4-22-04 PROOF TEST.
- 2) HYDRO @ 240 PSIG. MIN.

NOTE: 1) INSTALL (3) 1 5/16" x 48" LG. RIGID MAG. ANODES.

SHELL / HEADS	.250" SA-455 2:1 S.E.	GS-48-1080-H	REV. 2-26-18
	JOGGLE		DATE: 5-21-90
M.A.W.P.	160 PSIG. @ 210 °F	FOR: HANSON STANDARD	
	ASME SECTION IV 2017	HORIZ. HOT WATER TANK	
X-RAY:	RT-NO / H.L.W.	SURFACE AREA = 164.5 SQ. FT.	
GALLONS:	1080	WT. 1608 LBS.	INSIDE: GLASS LINED
SERIAL NO.			(5 MILS MIN.)
N.B.			OUTSIDE: PRIME
			CAD-"B" UNDER "STD SERIES"
			BY: J.G. SCALE: 3/4"=12"
			<b>ROY E. HANSON JR. MFG.</b>
			LOS ANGELES, CA 90021

VIEW W/O SUPPORTS