



VIEW W/O SUPPORTS

- 3) SHELL: 4-22-04 PROOF TEST.
 2) HYDRO @ 240 PSIG. MIN.
 NOTE: 1) INSTALL W/ (3) 1 5/16"x 30" LG. RIGID MAG. ANODES.

SHELL / HEADS	.250" SA-455 2:1 S.E.	GS-48-900-H	REV. 12-21-15
	JOGGLE (.230" MIN.)		DATE: 5-21-90
			FOR: HANSON STANDARD
			HORIZ. HOT WATER TANK
	.200" SA-455		SURFACE AREA = 138.4 SQ. FT.
			INSIDE: GLASS LINED
	M.A.W.P. 160 PSIG. @ 210 °F		
	ASME SECTION IV 2015		OUTSIDE: PRIME
	X-RAY: RT-NO / H.L.W.		CAD-"B" UNDER "STD"-SERIES
	GALLONS: 900	WT. 1350 LBS.	BY: E.S. SCALE: 3/4"=12"
	SERIAL NO.		ROY E. HANSON JR. MFG.
	N.B.		LOS ANGELES, CA 90021