



JOB # 9110

- 3) 5-6-04 PROOF TEST.
  - 2) SHIP LOOSE W/(3) 1 5/16" x 60" LG. FLEX. MAG. ANODES.
- NOTE: 1) HYDRO TEST @ 188 PSIG. MIN. TO 197 PSIG. MAX.

SHELL / HEADS	.250" SA-455 2:1 S.E. (.228" MIN.)	GS-60-1450-H	REV. 9-6-18
			DATE: 5-21-90
		FOR: HANSON STANDARD	
		HORIZ. HOT WATER TANK.	
	.218" SA-455	SURFACE AREA = 181.5 SQ. FT.	
		INSIDE: GLASS LINED (5 MILS MIN.)	
	M.A.W.P. 125 PSIG. @ 210 °F	OUTSIDE: S. BLAST & PRIME	
	ASME. SECTION IV 2017	CAD "B" SIZE UNDER "STD"-SERIES	
	X-RAY: RT-NO / H.L.W.	BY: J.G.	SCALE: 1/2"=12"
	GALLONS: 1450	WT. 2033 LBS.	<b>ROY E. HANSON JR. MFG.</b>
	SERIAL NO.	LOS ANGELES, CA 90021	
	N.B.		