



- 4) 4-1-04 PROOF TEST.
- 3) EXTEND ALL CPLGS. 5/8" INSIDE.
- 2) HYDRO @ 240 PSIG. MIN.

NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.

HEADS	.182" SA-455 2:1 S.E.		SHELL	.164" SA-414-G	
	JOGGLE				
M.A.W.P. 160 PSIG. @ 210 °F			ASME SECTION IV 2001 ADD. 2003		
X-RAY: RT-NO/H.L.W.			GALLONS: 335 WT. 1126 LBS.		
SERIAL NO.			BY: E.S. SCALE: 3/4"=12"		
			CS-36-335-H FOR: HANSON STANDARD HORIZ. HOT WATER TANK 70.6 SQ. FT. SURFACE AREA. THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT. INSIDE: CEMENT LINED (317) OUTSIDE: PRIME CAD-"B" UNDER "STD"-SERIES ROY E. HANSON JR. MFG. 1924 COMPTON AVE. LOS ANGELES, CA 90011		

END VIEW W/OUT SUPPORTS