



VIEW W/OUT SUPPORTS

3) EXTEND ALL CPLGS. 5/8" INSIDE.
 2) HYDRO @ 188 PSIG. MIN. TO 197 PSIG. MAX.
 NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.

SHELL / HEADS	LEFT-.248" SA-455 2:1 S.E. (.212" MIN.)	CS-64-1650-H	REV. 9-4-07
	RIGHT-.289" SA-455 2:1 S.E. (.235" MIN.)		DATE: 10-23-89
	.250" SA-455		FOR: HANSON STANDARD HORIZ. WATER TANK
	M.A.W.P. 125 PSIG. @ 210 °F		197.0 SQ. FT. SURFACE AREA. THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.
ASME. SECTION IV 2004 ADD. 2006	X-RAY: RT-NO / H.L.W.	INSIDE: CEMENT LINED (1583)	OUTSIDE: PRIME
GALLONS: 1650	WT. 3800 LBS.	CAD-"B" UNDER "STD"-SERIES	BY: J.G. SCALE: 1/2"=12"
SERIAL NO.		ROY E. HANSON JR. MFG.	
N.B.		1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021	