





NOTE: 1) HYDRO @ 240 PSIG.
2) 4–22–04 PROOF TEST.

SHELL / HEADS	
	.245" SA–455 2:1 S.E.
	JOGGLE
	.200" SA–455
M.A.W.P. 160 PSIG. @ 180 °F	
	SURFACE AREA = 136.7 SQ. FT.
	VERT. WATER TANK.
	INSIDE: EPOXY LINED
	OUTSIDE: PRIME
	LEG–ZONE 4–15 KM.
ASME. SECTION IV 2010 ADD. 2010	CAD–"B" UNDER "STD"–SERIES
X–RAY: RT–NO / H.L.W.	BY: E.S. SCALE: 3/4" =1'
GALLONS: 900 WT. 1369 LBS.	
SERIAL NO.	
N.B.	

ES–48–900–V REV. 7–13–11 DATE: 9–6–89

FOR: HANSON STANDARD

ROY E. HANSON JR. MFG.
1600 E. WASHINGTON BLVD.
LOS ANGELES, CA 90021