



NOTE: 1) HYDRO @ 166 PSIG. MIN.
 2) ALL FNPT'S SA-182-304 S.S.

| | |
|--|---|
| SHELL / HEADS | LEFT-.250" SA-455 2:1 S.E. (.226" MIN.) |
| | RIGHT-.289" SA-455 2:1 S.E. (.242" MIN.) |
| | ENDS-.263" SA-455 @ 56 1/4" |
| | CENTER-.289" SA-455 @ 62 1/2" |
| | M.A.W.P. 125 PSIG. @ 130 °F |
| M.D.M.T. +30 °F @ 125 PSIG. | |
| ASME. SECTION VIII DIV. 1, 2007 ADD 2007 | |
| X-RAY: RT-4 SPOT L.S. & HEADS G.S. | |
| GALLONS: 3500 | WT. 4930 LBS. |
| SERIAL NO. | |
| N.B. | |

| | |
|---|-----------------|
| WM-485-B | REV. 11-26-08 |
| | DATE: 10-14-08 |
| FOR: | |
| HORIZ. HYDROPNEUMATIC WATER TANK | |
| SURFACE AREA = 360.0 SQ. FT. | |
| UW-21(b) | |
| INSIDE: FDA & NSF 61 APPROVED EPOXY | |
| OUTSIDE: SSPC-10 BLAST, | |
| (1) COAT 3 MIL DFT ZINC PRIMER | |
| (1) COAT 5 MIL DFT EPOXY | |
| (1) COAT 2 MIL WHITE URETHANE TOPCOAT | |
| BY: E.S. / STEVE | SCALE: 1/2"=12" |
| ROY E. HANSON JR. MFG. | |
| 1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021 | |