



NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.

2) EXTEND ALL CPLGS. 5/8" INSIDE.

3) HYDRO @ 240 PSIG. MIN.

4) 4-1-04 PROOF TEST.

SHELL / HEADS		.182" SA-455 2:1 S.E.		CS-36-305-V		REV. 1-11-07	
JOGGLE - .149 OFFSET				DATE: 2-27-92		FOR: HANSON STANDARD	
.165" SA-414-G				VERT. HOT WATER TANK		65.2 SQ. FT. SURFACE AREA.	
M.A.W.P. 160 PSIG. @ 210 °F				INSIDE: CEMENT LINED		THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.	
ASME SECTION IV 2004 ADD 2006				OUTSIDE: PRIME			
X-RAY: RT-NO / H.L.W.				(289) LEG-ZONE 4-15 KM.			
GALLONS: 305		WT. 1023 LBS.		CAD-"B" UNDER "STD"-SERIES			
SERIAL NO.				BY: E.S.		SCALE: 1"=12"	
N.B.				ROY E. HANSON JR. MFG.		1600 E. WASHINGTON BLVD.	
						LOS ANGELES, CA 90021	