



NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.
 2) EXTEND ALL CPLGS. 5/8" INSIDE.
 3) HYDRO @ 240 PSIG. MIN.
 4) 4-1-04 PROOF TEST.

SHELL / HEADS		.182" SA-455 2:1 S.E.	
JOGGLE - .149 OFFSET		.164" SA-414-G	
M.A.W.P.	160 PSIG. @ 210 °F		
ASME SECTION IV	2004 ADD 2006		
X-RAY:	RT-NO/H.L.W.		
GALLONS:	335 WT. 1098 LBS.		
SERIAL NO.			
N.B.			
FOR: HANSON STANDARD		CS-36-335-V	
VERT. HOT WATER TANK		REV. 1-17-07	
70.6 SQ. FT. SURFACE AREA.		DATE: 12-3-99	
THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.			
INSIDE: CEMENT LINED			
OUTSIDE: PRIME			
(318) LEG-ZONE 4-15 KM.			
CAD-"B" UNDER "STD"-SERIES			
BY: J.G.		SCALE: 1"=12"	
ROY E. HANSON JR. MFG.			
1600 E. WASHINGTON BLVD.			
LOS ANGELES, CA 90021			