



SHELL / HEADS	
M.A.W.P.	160 PSIG. @ 210 °F
ASME SECTION	IV 2013
X-RAY:	RT-NO / H.L.W.
GALLONS:	360 WT. 1145 LBS.
SERIAL NO.	
N.B.	
JOGGLE	.189" SA-414-G 2:1 S.E.
	.166" SA-414-G

- NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.
- 4-1-04 PROOF TEST.
 - HYDRO @ 240 PSIG. MIN.
 - EXTEND ALL CPLGS. 5/8" INSIDE.
 - SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.

FOR: HANSON STANDARD	CS-36-360-V	REV. 6-24-15
VERT. HOT WATER TANK		DATE: 3-26-03
73.8 SQ. FT. SURFACE AREA.		
THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.		
INSIDE: CEMENT LINED		
OUTSIDE: PRIME		
(334) LEG-ZONE 4-15 KM.		
CAD-"B" UNDER "STD"-SERIES		
BY: E.S.	SCALE: 1"=12"	
ROY E. HANSON JR. MFG.		
1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021		

