



NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.  
 2) EXTEND ALL CPLGS. 5/8" INSIDE.  
 3) HYDRO @ 240 PSIG. MIN.  
 4) 4-1-04 PROOF TEST.

SHELL / HEADS		M.A.W.P. 160 PSIG. @ 210 °F	
.166" SA-414-G (.164" MIN.)		ASME SECTION IV 2015	
.189" SA-455 2:1 S.E.		X-RAY: RT-NO / H.L.W.	
JOGGLE		GALLONS: 400 WT. 1400 LBS.	
		SERIAL NO.	
		N.B.	
FOR: HANSON STANDARD		LEG-ZONE 4-15 KM.	
VERT. HOT WATER TANK		CAD-"B" UNDER "STD"-SERIES	
82.7 SQ. FT. SURFACE AREA. THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.		BY: J.G. SCALE: 1"=12"	
INSIDE: CEMENT LINED		ROY E. HANSON JR. MFG.	
OUTSIDE: PRIME		LOS ANGELES, CA 90021	
CS-36-400-V		REV. 11-29-17	
DATE: 8-12-98			