



NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.
 2) HYDRO @ 240 PSIG.
 3) EXTEND ALL CPLG'S 5/8" INSIDE.
 4) 4-1-04 PROOF TEST.

SHELL / HEADS		M.A.W.P. 160 PSIG. @ 210 °F	
.205" SA-455 2:1 S.E.		ASME SECTION IV 2004 ADD 2006	
.189 OFFSET - BROWN STRIPE		X-RAY: RT-NO / H.L.W.	
.175" SA-414-G		GALLONS: 462 WT. 1450 LBS.	
JOGGLE		SERIAL NO.	
FOR: HANSON STANDARD		N.B.	
VERT. HOT WATER TANK		BY: J.G.	
82.8 SQ. FT. SURFACE AREA.		SCALE: 3/4"=12"	
THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.		INSIDE: CEMENT LINED	
OUTSIDE: PRIME		(431) LEG ZONE: 4-15 KM.	
CS-42-462-V		CAD "B" UNDER "STD"-SERIES	
REV. 1-19-07		ROY E. HANSON JR. MFG.	
DATE: 10-10-90		1600 E. WASHINGTON BLVD.	
		LOS ANGELES, CA 90021	