



SHELL / HEADS	
.200" SA-455	
M.A.W.P.	160 PSIG. @ 210 °F
ASME SECTION	IV 2004 ADD. 2006
X-RAY:	RT-NO / H.L.W.
GALLONS:	800 WT. 2171 LBS.
SERIAL NO.	N.B.

- NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.
 2) HYDRO @ 240 PSIG.
 3) EXTEND ALL CPLGS. 5/8" INSIDE.
 4) 4-22-04 PROOF TEST.

FOR: HANSON STANDARD VERT. HOT WATER TANK.	
CS-48-800-V	REV. 1-23-07
DATE: 12-20-94	
125.3 SQ. FT. SURFACE AREA. THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.	
INSIDE:	CEMENT LINED
OUTSIDE:	PRIME
(763)	LEG-ZONE 4-15 KM.
CAD-"B" UNDER "STD"-SERIES	
BY: J.G.	SCALE: 3/4" = 1'
ROY E. HANSON JR. MFG.	
1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021	

