



SHELL / HEADS	
.250" SA-455	
M.A.W.P. 160 PSIG. @ 210 °F	
ASME SECTION IV 2001 ADD. 2003	
X-RAY: RT-NO / H.L.W.	
GALLONS: 1650	WT. 3764 LBS.
SERIAL NO.	
N.B.	

- NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.
- 2) HYDRO @ 240 PSIG.
 - 3) EXTEND ALL CPLGS. 5/8" INSIDE.
 - 4) 10-1-04 PROOF TEST.

CS-64-1650-V	
FOR: HANSON STANDARD	REV. 10-6-04
VERT. WATER TANK	DATE: 7-23-01
197.2 SQ. FT. SURFACE AREA. THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.	
INSIDE: CEMENT LINED	
OUTSIDE: PRIME	
(1584) LEG-ZONE 4-15 KM.	
CAD-"B" UNDER "STD"-SERIES	
BY: J.G.	SCALE: 1/2"=12"
ROY E. HANSON JR. MFG.	
1924 COMPTON AVE. LOS ANGELES, CA 90011	

