



NOTE: 1) HYDRO @ 327 PSIG. MIN.

HEADS	.245" SA-455 2:1 S.E.
	JOGGLE
SHELL	.289" SA-455
M.A.W.P. 250 PSIG. @ 200 °F	
M.D.M.T. -20 °F @ 250 PSIG.	
ASME. SECTION VIII DIV. 1, 2004 ADD. 2005	
X-RAY: RT-4 SPOT L.S. & HDS. G.S.	
GALLONS:	1150
WT.	2790 LBS.
SERIAL NO.	
N.B.	

<b>PA-514-B</b>	REV. 8-23-06
	DATE: 1-2-90
FOR: HANSON STANDARD	
HORIZ. PROPANE TANK DISPENSER	
CFM REQ. = 4033	
SURFACE AREA = 194.1 SQ. FT.	
INSIDE: UNPAINTED & DEHYDRATE	
OUTSIDE: PRIME	
BY: J.G.	SCALE: 1/2"=12"
<b>ROY E. HANSON JR. MFG.</b>	
1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021	