



NOTE: 1) HYDRO @ 325 PSIG. MIN.

HEADS	.245" SA-455 2:1 S.E.	PA-515-B	REV. 7-27-11
	JOGGLE - .289" OFFSET		DATE: 1-2-90
SHELL	.289" SA-455	FOR: HANSON STANDARD	
		HORIZ. PROPANE TANK DISPENSER	
		CFM REQ. = 3654	
		SURFACE AREA = 172.1 SQ. FT.	
		INSIDE: UNPAINTED & DEHYDRATE	
		OUTSIDE: PRIME & WHITE	
	M.A.W.P. 250 PSIG. @ 200 °F	BY: J.G. SCALE: 1/2"=12"	
	M.D.M.T. -20 °F @ 250 PSIG.	<b>ROY E. HANSON JR. MFG.</b>	
	ASME. SECTION VIII DIV. 1, 2010 ADD. 2010	1600 E. WASHINGTON BLVD.	
	X-RAY: RT-4 SPOT L.S. & HDS. G.S.	LOS ANGELES, CA 90021	
	GALLONS: 1000 WT. 2329 LBS.		
	SERIAL NO.		
	N.B.		