



NOZZLE SCHEDULE			
ITEM	QTY.	SIZE	DESCRIPTION
A	1	1"	PRV
B	1	1"	SITE LEVEL GAUGE
C	1	1"	SITE LEVEL GAUGE
D	3	1"	PRESSURE TRANSMITTER
E	1	1/2"	PRESSURE GAUGE
F	1	4"	DRAIN
G	1	4"	INLET
H	1	4"	OUTLET

- 5) INTERIOR: 1) SAND BLAST
2) PRIME - SERIES 91
3) FINISH - 2 COATS N140 MPOTA-POX
- 4) EXTERIOR: 1) SAND BLAST
2) PRIME - SERIES 69 RED
3) SERIES 69 WHITE
4) SERIES 1074 WHITE

3) COATING TESTED BY NACE AGENCY.
2) SEISMIC DESIGN P.E. REQUIRED.
NOTE 1) HYDRO @ 390 PSIG.

RIGHT-.5625" SA-516-70 2:1 S.E. (.496" MIN.)	WL-040-C	REV.
LEFT-.520" MIN. (5/8" NOM.)		DATE: 3-21-05
D. & F. - 52"D.R. & 10"K.R.	FOR:	
.500" SA-516-70	HORIZ. HYDROPNEUMATIC TANK	
	SURFACE AREA = 327.2 SQ. FT.	
	SOUTH RIVER	
	INSIDE: SEE NOTE: 5	
M.A.W.P. 300 PSIG. @ 200 'F	OUTSIDE: SEE NOTE: 4	
M.D.M.T. -20 'F @ 300 PSIG.		
ASME SECTION VIII DIV. 1, 2001 ADD 2003		
X-RAY: RT-2 100% ALL L.S. & SPOT G.S.	BY: J.G./BILL	SCALE: 1/2"=1'
GALLONS: 3000 WT. 10171 LBS.	ROY E. HANSON JR. MFG.	
SERIAL NO.	LOS ANGELES, CA 90011	
N.B.		