



42" TANK SUPT:  
 PER: MB-826-B

- 4) ALL PIPES SA-312-304 SMLS.
- 3) SHELL: 3-11-09 PROOF TEST.
- 2) HYDRO @ 240 PSIG. MIN.
- NOTE: 1) INSTALL (2) 1 5/16"x 36"LG. RIGID MAG. ANODES.

SHELL / HEADS	.205" SA-414-G 2:1 S.E.
	JOGGLE
M.A.W.P.	160 PSIG. @ 210 °F
	ASME SECTION IV 2019
X-RAY:	RT-NO / H.L.W.
GALLONS:	499
WT.	1060 LBS.
SERIAL NO.	
N.B.	

WP-681-B	REV. 2-2-21
	DATE: 6-5-18
FOR: HANSON STANDARD	
HORIZ. HOT WATER TANK	
SURFACE AREA = 91.4 SQ. FT.	
INSIDE: GLASS LINED (5 MILS MIN.)	
OUTSIDE: S. BLAST AND PRIME	
BY: J.G.	SCALE: 3/4"=12"
ROY E. HANSON JR. MFG.	
LOS ANGELES, CA 90021	